



NO. 1 2010 EDITION
 DESCRIPTION OF REVISIONS
 MADE BY C. COLE
 DATE 03/10
 NO. 3 4
 DESCRIPTION OF REVISIONS
 MADE BY
 DATE

MAKE	L	W
Tesco	17 1/8"	16 1/2"
Milbank	18"	16"
Myers	17 1/4"	16"
PUP	16 1/2"	16"




SIDE VIEW



FRONT VIEW


NOTES:

- All materials and construction shall conform to the requirements of the Specifications.
- The meter pedestal cabinet shall be furnished and installed as a completely pre-wired and pre-paneled with all plug-in components to the type and capacities specified herein and on the plans. There are two types of cabinets. Type I includes roadway lighting control circuitry, components including a photo electrical cell. The Type II does not include any of the lighting control circuitry.
- All exterior cabinet housing, doors, and panels shall be made of either 14 gauge galvanized steel or unpainted 5052-H32, 0.125 thick aluminum unless otherwise specified or approved. All fasteners, latches and hardware are to be stainless steel.
- The Type I cabinet shall be installed so the photo electric cell is aimed north. If this is not possible then, a Type II cabinet shall be used and the street lighting control is to be provided in traffic signal control cabinet
- The basic outdoor weathering rating for the cabinet shall be NEMA 3R.
- For the size and position of the anchor bolts see T.S. 2-6 Series Drawings. The required size and position shall be verified by the contractor prior to foundation construction.
- Cabinets supplied shall be pre-approved by the Department and the applicable utility company. Cabinets from Tesco, Milbank, Meyers and Pacific Utility Products (PUP) have been approved.
- The exact configuration of the cabinet can vary slightly from what is shown, if approved by the Department and the applicable utility, this includes dimensions.
- Use an approved silicon sealer RTV type, grey or clear, to seal the cabinet to the foundation.



BOTTOM VIEW
(Mounting Slot Detail)

MAKE	X
Tesco	14"
Milbank	14 1/2"
Myers	14 3/4"
PUP	14 1/4"



NOT TO SCALE

DESIGN APPROVED SIGNATURE	ARIZONA DEPARTMENT OF TRANSPORTATION INTERMODAL TRANSPORTATION DIVISION TRAFFIC SIGNALS AND LIGHTING STANDARD DRAWINGS	REVISION 03/10
APPROVED FOR DISTRIBUTION ON FILE	TYPE I AND II METER PEDESTAL CABINET	DRAWING NO. T.S. 3-5
		SHEET NO. 1 OF 2